



July 2023 – June 2024

## Te Aakau Water Supply Annual Report

### Te Aakau Water Supply

The Te Aakau water supply was granted Resource Consent #I10226 (ground water take) in February 2009 to operate with the following conditions:

- Maximum take volume not to exceed 476m<sup>3</sup> in total in any 7 day period
- Maximum take volume not to exceed on average 68 m<sup>3</sup> in any 24 hour period
- This consent is due to expire in January 2024.

The Resource Management (Measurement & Reporting of Water Takes) Regulations 2010 require Waikato District Council to provide annual records to Waikato Regional Council for the life of the permit. Records must be provided no later than one month after the end of the water year (ending on 30 June). This report satisfies Regulation 6 & 8 of the Resource Management (Measurement & Reporting of Water Takes) Regulations 2010.

As of 9<sup>th</sup> April 2021, the source of water supply for Te Aakau has been changed to Tanker supply to the reservoir. Abstraction from the bore has been temporarily discontinued until further notice.

The flow meter at Te Aakau is a mechanical flow meter and the plant is in the planning stages of being upgraded, so there is no verification certificate for this site.